

## **SPRING HILL FIRE RESCUE and EMS DISTRICT Checklist for Public Fireworks Display Permit**

1. Application for permit from Spring Hill Fire Rescue to be filled out completely and returned with all supporting documentation at least 30 days before proposed display.
2. Permittee is to certify that he is in compliance with all provisions under which the permit may be granted including filing of reports required by Florida Statutes 791 and Florida Administrative Code 69A-60 and will comply with all Florida Fire Prevention Code requirements referenced in NFPA 1123, 1126 and any other applicable codes.
3. Pyrotechnic operator to provide a copy of the State Pyrotechnic Operator license and names of Pyrotechnic Operator assistants.
4. Product information to be provided including the class of fireworks to be displayed, number of items and set pieces, other items to be displayed, name of wholesaler supplying all items and the wholesaler's state license number.
5. Location of any fireworks stored prior to and during the display if applicable.
6. Policy number and copies of Public Liability Insurance and Employees Compensation Insurance listing Spring Hill Fire Rescue.
7. An accurately dimensioned plot plan diagramming the display area is to be provided. Plot plan shall include location of all buildings on the site, the placement of devices, location from where the operator will discharge fireworks, location of any performers, location of the audience and the lines behind which the audience will be restrained. Additionally show the location of roads, overhead obstructions, nearby trees and telephone and power lines, and distances to any structures on adjacent properties. When necessary a sectional drawing shall be provided.
8. Include a complete description of all fireworks to be displayed, specifying if single or multiple break shells. Any set pieces used shall be described in detail. Provide complete description of additional items to be displayed.
9. A copy of the Certificate of Insurance must be filed with the application which complies with the following requirements (reference Section 791, Florida Statutes and Florida Administrative Code 69A-60):
  - a. Limits of bodily injury and property damage may be not less than one million dollars (\$1,000,000.00) combined single limits for each occurrence.
  - b. A statement must be included that the insurer will not cancel the insured's coverage without 15 days prior written notice to the Fire Prevention office.
  - c. Spring Hill Fire Rescue shall not be responsible for any premiums or assessments involving the policy.
  - d. The licensed pyrotechnic operator supervising/discharging the display must be included as additional insureds.